

24 Ensure Toilets & Sinks Work Without Power

I. Summary

Issue:

Some toilets and faucets need electricity to function. This presents a sanitation risk during an extended power outage.

Recommendation:

Require that toilets and faucets be capable of operating without grid power.

II. Proposed Legislation, Rule or Study

Amendments to the New York City Plumbing Code:

1. Add a new subsection 424.7 as follows:

424.7 Lavatory sensor control devices. In each bathroom, one or more sensor control devices used for lavatory faucets shall be able to continue normal operation in the event of a loss of building electrical power for a period of at least two weeks, without connection to the building electrical power supply. Exception: This requirement shall not apply to a lavatory faucet that is designed to be operated manually and without electrical power.

2. Add a new subsection 425.5 as follows:

425.5 Water closet and urinal flushing sensor control devices. In each bathroom, one or more sensor control devices used for flushing toilets or urinals shall be able to continue normal operation in the event of a loss of building electrical power for a period of at least two weeks, without connection to the building electrical power supply. Exception: This requirement shall not apply to a toilet or urinal that is designed to be operated manually and without electrical power.

III. Supporting Information

Expanded Issue and Benefits:

Automatic bathroom fixtures were created in part to reduce human contact with bathroom surfaces that might spread disease. However, the need of many such fixtures for electricity leaves them vulnerable to disruptions in the power grid, potentially crippling building sanitation during blackouts. The effect of losing sanitation in an occupied building was graphically demonstrated in the aftermath of Hurricane Sandy when lack of water pressure caused toilets to fail. This proposal is intended to promote sanitary conditions by ensuring the proper functioning of automatic bathroom fixtures during prolonged power disruptions.

This proposal does not recommend the elimination of power-activated bathroom fixtures because these fixtures provide important health and conservation benefits. The purpose is rather to ensure that these devices can function in the event of utility loss.

In order to minimize required expenses in existing buildings, this proposal does not suggest retroactive application. However, retrofitting at least one toilet and faucet per bathroom is considered a best practice in existing buildings to maintain the use of sanitary facilities during an extended power outage.

Implementation:

Lavatory faucet sensors and toilet sensors with the required battery life are readily available. Some flushometer toilets with sensors also provide a manual override. There should not be any implementation problems with these devices as they are currently required to be installed by a licensed plumber and installation of these devices has been common for years. Devices must have a true manual override that allows the device to be operated in the complete absence of external power, not a button that still requires electricity supply to the device for it to function.

Cost:

Turner Construction Company prepared cost estimates based upon several standardized building typologies. Due to the innate variances in construction costs between projects, the complexity of the Task Force proposals, and the wide range of buildings to which the proposals may apply, these cost estimations should only be used as rough order-of-magnitude guides. The cost analysis is presented at the end of this proposal; more information about the cost methodology is given at the end of the full report.

The following analysis was provided by the authors of this proposal:

The cost of using battery-powered devices rather than hard-wired ones is minimal. There is a potential maintenance cost associated with the changing of batteries in battery-powered devices. However, since true manual override devices are available, as well as battery-powered devices with batteries lasting up to 10 years, the maintenance expenses are very low or zero.

24 ENSURE TOILETS & SINKS WORK WITHOUT POWER

	Commercial High Rise			Commercial Low Rise			Residential High Rise			Residential Low Rise		
	Quantity	Unit	Total Unit Cost	Quantity	Unit	Total Unit Cost	Quantity	Unit	Total Unit Cost	Quantity	Unit	Total Unit Cost
NEW CONSTRUCTION												
24.1 Ensure Toilets & Sinks Work Without Power												
Battery Powered												
Premium for 1 battery powered flushometer per unit												
Premium for 1 battery powered faucet per unit												
Premium for 1 battery powered flushometers per gang bathroom	60	EA	\$0.00	4	EA	\$0.00						
Premium for 1 battery powered urinal flushometers per gang bathroom	30	EA	\$0.00	2	EA	\$0.00						
Premium for 1 battery powered faucet per gang bathroom	60	EA	\$200.00	4	EA	\$200.00						
Remediation of old electric-only fixtures			Not Required			Not Required						
SUBTOTAL DIRECT WORK			\$12,000			\$800						\$35,000
Contingency		10%	\$1,200		10%	\$80						\$3,500
SUBTOTAL			\$13,200			\$880						\$38,500
GC Mark-ups		0.2	\$2,640		0.2	\$176						\$7,700
TOTAL	620,000	GSF	\$0.03	4,000	GSF	\$0.26	\$1,056	231,000	GSF	\$0.20	\$46,200	N/A

	Commercial High Rise			Commercial Low Rise			Residential High Rise			Residential Low Rise		
	Quantity	Unit	Total Unit Cost	Quantity	Unit	Total Unit Cost	Quantity	Unit	Total Unit Cost	Quantity	Unit	Total Unit Cost
EXISTING BUILDINGS												
24.1 Ensure Toilets & Sinks Work Without Power												
Battery Powered												
Furnish and install 1 Zum ZTR6200EV battery powered flushometer per unit												
Furnish and install 1 Zum Z6914 battery powered faucet per unit												
Furnish and install 1 Zum ZTR6200EV battery powered flushometer per gang bathroom	60	EA	\$1,000.00			\$60,000						
Furnish and install 1 Zum ZTR6203 urinal flushometer per men's gang bathroom	30	EA	\$1,000.00			\$30,000						
Furnish and install 1 Zum Z6914 battery powered faucet per gang bathroom	60	EA	\$750.00			\$45,000						
Remediation of old electric-only fixtures	150	ALW	\$600.00			\$90,000						
Remediation labor	1,200	HRS	Included			Included						
SUBTOTAL DIRECT WORK			\$225,000			\$225,000						\$516,300
Contingency		10%	\$22,500		10%	\$22,500						\$51,630
SUBTOTAL			\$247,500			\$247,500						\$567,930
GC Mark-ups		20%	\$49,500		20%	\$49,500						\$113,586
TOTAL	620,000	GSF	\$0.48	620,000	GSF	\$0.48	\$297,000	B	231,000	GSF	\$2.95	\$681,516

